


COMPACTED GRANULAR (CA-6) BACKFILL IN AREAS UNDER PAVEMENT COMPACTED SELECTED BACKFILL 6" WARNING TAPE AS SPECIFIED. -SAND BACKFILL (ONLY WHEN CONDUIT OR UNIT DUCT IS PLACED IN TRENCH) CONDUIT OR UNIT DUCT TRENCH AND BACKFILL

HEAT-SHRINKABLE CAP WITH FACTORY APPLIED WATERPROOF SEALANT, (SIZED TO ACCOMMODATE NUMBER OF CABLES) COMPRESSION TYPE COPPER SLEEVE (SIZED FOR ACTUAL NUMBER OF CABLES AND MFR. -SUGGESTED CRIMP TOOL USED) TRIMMED CABLES -SEALANT TAPE OR INSERT (AROUND AND THROUGH CROTCH SPLICE) ELECTRIC FEEDER CABLE. SUCH AS UNIT DUCT (SIZE AS NOTED -EXPOSED SEALANT ON CONTRACT DRAWINGS) -ELECTRIC CABLE TO LUMINAIRE NOTE: NUMBER OF CABLES (SIZE AS NOTED ON THE IN SPLICE MAY VARY CONTRACT DRAWINGS) -

SPLICING ELECTRIC CABLE

POLE BASE WIRING WITH QUICK DISCONNECTS AND BREAKAWAY DEVICE TRANSFORMER BASE



THIS DRAWING IS THE EXCLUSIVE PROPERTY OF SUMLOY INC. AND IS PROVIDED ONLY FOR THE PROJECT LISTED ON THIS DRAWING. THIS DRAWING SHAL NOT BE DUPLICATED, USED OR DISCLOSED, IN WHOLE OR IN PART, FOR ANY PURPOSE WHATSGEVER WITHOUT THE WRITTEN PERMISSION OF SUNJOY INC.



ILLINOIS DEPARTMENT OF TRANSPORTATION 73rd STREET (FAU 1569) VILLAGE OF BEDFORD PARK

COUNTY

FED, ROAD DIST. NO. ILLINOIS FED. AID PROJECT

COOK

CONTRACT NO. - 83711

SECTION 1569 02-00025-00-LT

ELECTRICAL DETAILS

REVISION 05-28-05 SCHAUMBURG, ILLINOIS REVISION 05-21-05 60193-1572

SCALE: NONE DATE: 04-15-05

DRAWN BY: HMQ CHECKED BY: JS

E-14 OF 14